



**METRO GROUP**  
BUILDING SOLUTIONS YOU TRUST

50-23 Twenty-Third Street  
Long Island City, NY 11101  
TEL: (718) 729-7200  
FAX: (718) 729 8677

## Certificate of Lead Analysis

|                        |                                                                                |                                      |                     |                              |              |
|------------------------|--------------------------------------------------------------------------------|--------------------------------------|---------------------|------------------------------|--------------|
|                        |                                                                                |                                      |                     | <b>ELAP ID</b>               | <b>12093</b> |
| <b>CLIENT:</b>         | GROWING UP GREEN CHARTER SCHOOL II<br>89-17 161ST STREET<br>ELMHURST, NY 11432 | <b>Date Collected</b>                | 7/23/2026           | <b>Time Collected</b>        | 10:00 AM     |
|                        |                                                                                | <b>Date Received</b>                 | 7/24/2026           | <b>Time Received</b>         | 2:00 PM      |
|                        |                                                                                | <b>Date Analyzed</b>                 | 7/28/2026           | <b>Volume Collected (mL)</b> | 250          |
|                        |                                                                                | <b>Date Reported</b>                 | 7/30/2026           | <b>Volume Examined (mL)</b>  | 5            |
| <b>Representative:</b> |                                                                                | JASON YOU                            |                     |                              |              |
| <b>Project ID #</b>    |                                                                                | GROW01-01                            |                     |                              |              |
|                        |                                                                                |                                      |                     |                              |              |
| <b>No.</b>             | <b>Analysis #</b>                                                              | <b>Sample Location</b>               | <b>Result (ppb)</b> | <b>Remark</b>                |              |
| 1                      | 83276-1                                                                        | GIRLS BATHROOM 208 SINK 4            | < 1                 |                              |              |
| 2                      | 83276-2                                                                        | GIRLS BATHROOM 208 SINK 2            | < 1                 |                              |              |
| 3                      | 83276-3                                                                        | GIRLS BATHROOM 208 SINK 5            | 1.3                 |                              |              |
| 4                      | 83276-4                                                                        | GIRLS BATHROOM 208 SINK 1            | < 1                 |                              |              |
| 5                      | 83276-5                                                                        | GIRLS BATHROOM 208 SINK 3            | 1.8                 |                              |              |
| 6                      | 83276-6                                                                        | GIRLS BATHROOM 208 SINK 6            | 2.5                 |                              |              |
| 7                      | 83276-7                                                                        | 3RD FL BOYS BATHROOM SINK 2          | 2.1                 |                              |              |
| 8                      | 83276-8                                                                        | 1ST FL BOYS BATHROOM SINK 1 RM 108   | 2.6                 |                              |              |
| 9                      | 83276-9                                                                        | 2ND FL BOYS BATHROOM SINK 1 OUTLET 1 | 1.1                 |                              |              |
| 10                     | 83276-10                                                                       | 1ST FLR BOYS BATHROOM SINK 2 RM 108  | 1.3                 |                              |              |

**CONDITION OF SAMPLE(S):** Acceptable  
**SOURCE:** Domestic Water  
**TEST METHOD:** PALIN TEST# 1001 (ELAP Method # 2464)  
**COMMENTS:**

Note: The above test result is for Lead in Drinking Water, expressed in parts per billion (ppb). This result does not predict the future safety of the water system; it only represents the count in the sample on the test date. The sample was tested using method #1001 (ELAP Method #2464) for detection of Lead in Drinking Water, with a Detection Limit of 1 to 100 ppb. Any result found to be less than 1 ppb is expressed as ND indicating Not Detected. The Action Level for Lead in Drinking Water is 15 ppb according to the USEPA. Note further that drinking water in New York State schools requires adherence to an Action Level of 5 ppb.



All Samples tested in New York State  
were completed by ELAP Certified  
Laboratories using ELAP Method 2464

  
Gary Ho, CWT  
Lab Director