



METRO GROUP

BUILDING SOLUTIONS YOU TRUST

50-23 Twenty-Third Street
Long Island City, NY 11101
TEL: (718) 729-7200
FAX: (718) 729 8677

Certificate of Lead Analysis

				ELAP ID	12093
CLIENT:	GROWING UP GREEN CHARTER SCHOOL II 89-17 161ST STREET ELMHURST, NY 11432	Date Collected	7/23/2026	Time Collected	10:00 AM
		Date Received	7/24/2026	Time Received	2:00 PM
		Date Analyzed	7/28/2026	Volume Collected (mL)	250
		Date Reported	7/30/2026	Volume Examined (mL)	5
Representative:		JASON YOU			
Project ID #		GROW01-01			
No.	Analysis #	Sample Location	Result (ppb)	Remark	
1	83278-1	CLASSROOM 106 1ST FL WATER FOUNTAIN	3.2		
2	83278-2	CLASSROOM K01 WATER FOUNTAIN	1.1		
3	83278-3	3RD FL SCIENCE ROOM SINK 1	1.3		
4	83278-4	GYM BATHROOM SINK LEFT	1		
5	83278-5	3RD FL SCIENCE RM SINK 2	2.1		
6	83278-6	CLASSROOM 303 1 SINK	5.4		
7	83278-7	ES2 2ND FL WATER FOUNTAIN	< 1		
8	83278-8	BOYS BATHROOM 208 SINK 2	2.9		
9	83278-9	2ND FL CLASSROOM 101 DRINK FOUNTAIN	2.7		
10	83278-10	BOYS BATHROOM 3RD FLR SINK 1	1.4		

CONDITION OF SAMPLE(S): Acceptable
SOURCE: Domestic Water
TEST METHOD: PALIN TEST# 1001 (ELAP Method # 2464)
COMMENTS:

Note: The above test result is for Lead in Drinking Water, expressed in parts per billion (ppb). This result does not predict the future safety of the water system; it only represents the count in the sample on the test date. The sample was tested using method #1001 (ELAP Method #2464) for detection of Lead in Drinking Water, with a Detection Limit of 1 to 100 ppb. Any result found to be less than 1 ppb is expressed as ND indicating Not Detected. The Action Level for Lead in Drinking Water is 15 ppb according to the USEPA. Note further that drinking water in New York State schools requires adherence to an Action Level of 5 ppb.



All Samples tested in New York State
were completed by ELAP Certified
Laboratories using ELAP Method 2464

Gary Ho, CWT
Lab Director