



METRO GROUP

BUILDING SOLUTIONS YOU TRUST

50-23 Twenty-Third Street
Long Island City, NY 11101
TEL: (718) 729-7200
FAX: (718) 729 8677

Certificate of Lead Analysis

				ELAP ID	12093
CLIENT:	GROWING UP GREEN CHARTER SCHOOL II 89-17 161ST STREET ELMHURST, NY 11432	Date Collected	7/23/2026	Time Collected	10:00 AM
		Date Received	7/24/2026	Time Received	2:00 PM
		Date Analyzed	7/28/2026	Volume Collected (mL)	250
		Date Reported	7/30/2026	Volume Examined (mL)	5
Representative:		JASON YOU			
Project ID #		GROW01-01			
No.	Analysis #	Sample Location	Result (ppb)	Remark	
1	83280-1	1ST FLR K04 SINK FOUNTAIN	2.2		
2	83280-2	3RD FLR CLASSROOM 303 SIK 2	56.6		
3	83280-3	3RD FLR GIRLS BATHROOM SINK 2	< 1		
4	83280-4	CLASROOM 101 SINK	< 1		
5	83280-5	1ST FLR K04 CLASS SINK	5.5		
6	83280-6	3RD FLR GIRLS BATHROOM SINK 1	5.9		

CONDITION OF SAMPLE(S): Acceptable
SOURCE: Domestic Water
TEST METHOD: PALIN TEST# 1001 (ELAP Method # 2464)
COMMENTS:
GROWING UP GREEN CHARTER



All Samples tested in New York State
were completed by ELAP Certified
Laboratories using ELAP Method 2464


Gary Ho, CWT
Lab Director